

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: **37501** County: **Cabarrus**
Water System ID #: **20-13-011**
Name of System: **Mt Mitchell UMC**
Sample Type: **5** (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: **01/19/10** TIME: **11:45 AM**
Location where collected: **Kitchen Fellowship Hall**
Location Type: ☐ (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: **004** Collected By: **P. Judge**

FOR REPEAT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity: ☐
(1 = Same; 2 = Upstream; 3 = Downstream)

FOR REPLACEMENT SAMPLE:

Original Sample Type: ☐
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time: _____

Mail Results To:

MOORESVILLE REGIONAL OFFICE PWSS
610 EAST CENTER AVENUE
MOORESVILLE, NC 28115

Telephone No. **704-663-1699**

Type of Supply:

☐ Community ☐ NTNC
☒ Non-Community ☐ Private

Type of Treatment:

☐ Chlorinated
☒ Non-Chlorinated

Free Chlorine Residual: 0.0 mg/l
Total Chlorine Residual: 0.0 mg/l

RESULTS

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	312	☐	☒	☐
Fecal/E. Coli		☐	☐	☐
Heterotrophic P.C.		_____/ml (number)		

☐ Repeat Samples Required

Date Analysis Begun: **01/20/10**
Date Analysis Completed: **01/21/10**
Laboratory Log #: **12944**

COMMENTS: _____

INVALID CODES

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

☐ Replacement Samples Required

Time Analysis Begun: **07:44 AM**
Time Analysis Completed: **09:05 AM**
Certified By: **Susan Beasley**

