



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
4312 District Drive  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7834  
Fax: 919-733-8695

---

Report To:  
**HENDERSON CO ENVIRONMENTAL HEALTH**  
**1200 SPARTANBURG HWY - SUITE 1**  
  
**HENDERSONVILLE, NC 28792**  
EIN:566000307EH

COURIER #: 06-92-01

Name of System:  
**JEFFREY STEPP**  
  
**374 LINDSEY LOOP RD.**  
**HENDERSONVILLE, NC 28792**

---

StarLiMS Sample ID: **ES012913-0043001**

Collected: 01/28/2013 09:01 **Curt Cline**  
Received: 01/29/2013 09:00 **Angela Heybroek**

ES Microbiology ID:  
GPS Number:

Sample Source: **Well** Well Permit Number:  
Sampling Point: **Well**

Sample Description:

Comment:

---

**Environmental Microbiology - Colilert Profile** **Method: SM 9223B**

**Test Name: Colilert**

<b>Analyte</b>	<b>Test Result</b>	<b>Analyst</b>	<b>Date</b>
Total Coliform, Colilert	Present	HLBRASWELL	01/30/2013
<i>E. coli</i> , Colilert	Absent	HLBRASWELL	01/30/2013

Report Date: 02/04/2013

Reported By: Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.