



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100

HENDERSONVILLE, NC 28792
EIN:566000307EH

COURIER #: 06-92-01

Name of System:

SUSAN SWAN / CARL LANCASTER
97 PINE HILL DR.
HORSE SHOE, NC

StarLIMS Sample ID: **ES020217-0113001**



Collected: 02/01/2017 08:59

Received: 02/02/2017 08:34

Curt Cline

Angela Heybroek

ES Microbiology ID:

GPS Number:

Sample Source: **New Well**

Sampling Point: **well**

Well Permit Number:

13120112519

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Date
Total Coliform, Colilert	Absent	02/03/2017
<i>E. coli</i> , Colilert	Absent	02/03/2017

Report Date: 02/03/2017

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.