



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - SUITE 100
HENDERSONVILLE, NC 28792
EIN:566000307EH

Name of System:

RICHARD & LINDA ETT

1570 TRAMMEL GAP RD
SALUDA, NC

StarLiMS Sample ID: **ES021511-0080001**



Collected: 02/14/2011 08:49

Received: 02/15/2011 08:12

Curt Cline

Joy Hayes

ES Microbiology ID: **24441**

GPS Number:

Sample Source: **Well**

Sampling Point: **Side tap**

Well Permit Number:

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Present	Darneice Lyons	02/16/2011
<i>E. coli</i> , Colilert	Absent	Darneice Lyons	02/16/2011

Report Date: 02/16/2011

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.