



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7834
Fax: 919-733-8695

Report To: **HENDERSON CO ENVIRONMENTAL HEALTH** Name of System: **ALIENE BILODEAU**
1200 SPARTANBURG HWY - SUITE 100 **46 CRIMSON LN.**
HENDERSONVILLE, NC 28792 **HENDERSONVILLE, NC 28792**
EIN:566000307EH COURIER #: **06-92-01**

StarLiMS Sample ID: **ES021612-0078001** Collected: **02/15/2012** 08:59 **Curt Cline**
 Received: **02/16/2012** 08:13 **Angela Heybroek**
ES Microbiology ID: **34375** Sample Source: **New Well** Well Permit Number: **11100111411**
GPS Number: Sampling Point: **Well**

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile Method: **SM 9223B**

Test Name: **Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Darneice Lyons	02/17/2012
<i>E. coli</i> , Colilert	Absent	Darneice Lyons	02/17/2012

Report Date: **02/17/2012**

Reported By: **Susan Beasley**



Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.