

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: Yadkin
Water System ID #: 02-99-545
Name of System: Burnette's Place
Sample Type: 5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: 02/16/10 TIME: 10:30 AM
Location where collected: Kitchen Compartment Sink
Location Type: 1 (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: E01 Collected By: David Reyes

FOR REPEAT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity: ☐ (1 = Same; 2 = Upstream; 3 = Downstream)

FOR REPLACEMENT SAMPLE:

Original Sample Type: ☐
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time: _____

Mail Results To:

WINSTON SALEM REGIONAL OFFICE PWSS

WINSTON SALEM, NC 27107-2241

Telephone No. 336-771-5000

Type of Supply:

☐ Community ☐ NTNC
☒ Non-Community ☐ Private

Type of Treatment:

☐ Chlorinated
☒ Non-Chlorinated
Free Chlorine Residual: 0 mg/l
Total Chlorine Residual: _____

RESULTS

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	<u>312</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Fecal/E. Coli	_____	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heterotrophic P.C.	_____	_____/ml (number)		

☐ Repeat Samples Required

Date Analysis Begun: 02/17/10
Date Analysis Completed: 02/18/10
Laboratory Log #: 13823

COMMENTS: _____

INVALID CODES

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

☐ Replacement Samples Required

Time Analysis Begun: 07:55 AM
Time Analysis Completed: 09:30 AM
Certified By: Susan Beasley

