N.C. Department of Environmental, Health, and Natural Resources
Division of Laboratory Services
State Laborabory of Public Health
P.O.Box 28047 - 4312 District Drive
Raleigh, NC 27611-8047
919-733-7308

DO NOT WRITE IN THIS SPACE

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #:	<u>37501</u>	County:	PENDER			
Water System ID #:	04-71-447	_				
Name of System:	HAMPSTEAD STA	AMPSTEAD STATION SHOPPING CENTER				
ample Type: [5] (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)						
Collected on: DATE:	02/22/17	TIME: 12:14	PM			
Location where collected:	n where collected: WELLHEAD FAUCET					
Location Type:	(1 = Entry Tap;		3 = End Tap; 4 = S	ource/Intakes; 5 = Other)		
Location Code:		Collected By:	Allen Ba	aker		
FOR REPEAT SAMPLE:			FOR REPLACE	EMENT SAMPLE:		
Previous Positive Location Code:			Original Sample Type:			
Positive Collection Date:			(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)			
Time:			Original Collection Date:			
Proximity:				Time		
(1 = Same; 2 = Upstream	; 3 = Downstream)					
Mail Results To: Type of Supp				:		
WILMINGTON REGIONAL OFFICE PWSS				Community [X NTNC	
127 CARDINAL DRIVE EXTENSION Non-Community					Private	
WILMINGTON, NC 28405 Type of Treatment: Chlorinated						
	107967215		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	Non-Chlorinate	ed	
EIN #: 566000372Q COURIER #: 04-1			2	Free Chlorine Resid	ual:	
EIN #. 500000372Q	COUR	IER #. 04-10-3	3	Total Chlorine Resid	lual:	
RESULTS			INVALID CODES			
CONTAMINANT METHO	DD PRESENT	ABSENT IN	IVALID	1) Confluent Growth/No C	Coliform Found	
Total Coliform 9223	3 X			2) TNTC/No Coliform Fou		
Fecal/E. Coli 9223	в 🗌	X		3) Turbid Culture/No Colif4) Over 30 Hours Old	orm Found	
Heterotrophic P.C/ml				5) Improper Sample or Analysis		
	(number)			, , , ,	,	
Repeat Samples Required				Replacement Samples Required		
Date Analysis Begun: 02/23/17				Time Analysis Begun:	08:05 AM	
Date Analysis Completed: 02/24/17				Time Analysis Completed	09:00 AM	
Laboratory Log #:				Certified By: Susa	n Beasley	
COMMENTS: Special /	Non-compliance (SP)	, Water Source: 0	SW	Tien	en Beasley	