



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
HENDERSONVILLE, NC 28792
EIN:566000307EH

Name of System:
GROVER BARNWELL
1680 FRUITLAND RD
COURIER #: 06-92-01

StarLiMS Sample ID: **ES030216-0067001**

Collected: 03/01/2016 09:00 **Cody Robertson**
Received: 03/02/2016 08:48 **Angela Heybroek**

ES Microbiology ID:
GPS Number:

Sample Source: **New Well**
Sampling Point: **Well tap**
Well Permit Number: **15120113932**

Sample Description:

Comment:

Environmental Microbiology - Colisure Profile

Method: SM 9223B

Test Name: Water - Colisure

Analyte	Test Result	Analyst	Date
Total Coliform, Colisure	Absent	Darneice Owens	03/03/2016
<i>E. coli</i> , Colisure	Absent	Darneice Owens	03/03/2016

Report Date: 03/04/2016

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.