



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
4312 District Drive  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

Report To:  
**HENDERSON CO ENVIRONMENTAL HEALTH**  
**1200 SPARTANBURG HWY - SUITE 1**

Name of System:  
**MIKE SMITH**

**HENDERSONVILLE, NC 28792**  
**EIN:566000307EH**

COURIER #: 06-92-01

**72 FOSTER RIDGE RD**  
**HENDERSONVILLE, NC 28792**

StarLIMS Sample ID: **ES031314-0081001**



Collected: 03/12/2014 09:07  
Received: 03/13/2014 09:05

**Krissie Red**  
**Angela Heybroek**

ES Microbiology ID:  
GPS Number:

Sample Source: **Well**  
Sampling Point: **Well**

Well Permit Number:

Sample Description:  
Comment:

**Environmental Microbiology - Colilert Profile**

Method: SM 9223B

Test Name: Colilert

| Analyte                   | Test Result | Analyst       | Date       |
|---------------------------|-------------|---------------|------------|
| Total Coliform, Colilert  | Absent      | Dameice Lyons | 03/14/2014 |
| <i>E. coli</i> , Colilert | Absent      | Dameice Lyons | 03/14/2014 |

Report Date: 03/21/2014

Reported By: **Susan Beasley**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.