



North Carolina State Laboratory Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.state.nc.us>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:**HENDERSON CO ENVIRONMENTAL HEALTH****1200 SPARTANBURG HWY - SUITE 100
HENDERSONVILLE, NC 28792****Name of System:****BOB CAMPBELL YOUTH CAMPUS
122 CAMP BOB DRIVE
HENDERSONVILLE, NC 28793**StarLIMS Sample ID: **ES033010-0065001**

Collected: 03/29/2010 08:15

Received: 03/30/2010 08:16

Garrett Rapp**Darneice Lyons**ES Microbiology ID: **15225**

GPS Number:

Sample Source: **Well**Sampling Point: **Kitchen tap**

Well Permit Number:

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile**Method:** SM 9223B**Test Name: Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Darneice Lyons	03/31/2010
<i>E. coli</i> , Colilert	Absent	Darneice Lyons	03/31/2010

Report Date: 04/01/2010**Reported By:** Susan Beasley**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.