



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - SUITE 1

HENDERSONVILLE, NC 28792
EIN:566000307EH

Name of System:
ROGER WORTHY

2874 HOWARD GAP RD
HENDERSONVILLE, NC 28792
COURIER #: 06-92-01

StarLiMS Sample ID: **ES041113-0071001**

Collected: 04/10/2013 08:30
Received: 04/11/2013 08:35
Krissie Red
Holly Braswell

ES Microbiology ID:
GPS Number:

Sample Source: **Well**
Sampling Point: **Well**
Well Permit Number:

Sample Description:

Comment:

Environmental Microbiology - Colisure Profile **Method: SM 9223B**

Test Name: Water - Colisure

Analyte	Test Result	Analyst	Date
Total Coliform, Colisure	Absent	HLBRASWELL	04/12/2013
<i>E. coli</i> , Colisure	Absent	HLBRASWELL	04/12/2013

Report Date: 04/15/2013

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.