



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To: **HENDERSON CO ENVIRONMENTAL HEALTH**
1200 SPARTANBURG HWY - SUITE 1
HENDERSONVILLE, NC 28792
EIN:566000307EH Name of System: **NAZARENE CAMP**
44 NAZARENE DRIVE
FLAT ROCK, NC 28731
COURIER #: 06-92-01

StarLiMS Sample ID: **ES041514-0102001** Collected: 04/14/2014 08:35 **Garrett Rapp**
 Received: 04/15/2014 08:50 **Susan Beasley**

ES Microbiology ID: Sample Source: **Well** Well Permit Number:
GPS Number: Sampling Point: **Kitchen**

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile Method: SM 9223B

Test Name: **Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Susan Beasley	04/16/2014
<i>E. coli</i> , Colilert	Absent	Susan Beasley	04/16/2014

Report Date: 04/17/2014

Reported By: Susan Beasley



Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.