



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.state.nc.us>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - SUITE 100
HENDERSONVILLE, NC 28792

Name of System:

GREG MAXWELL

98 AZALEA WOODS DR
HENDERSONVILLE, NC 28792

StarLiMS Sample ID: **ES042110-0072001**

Collected: 04/20/2010 09:05
Received: 04/21/2010 09:13
Krissie Red
Angela Heybroek

ES Microbiology ID: **15926**
GPS Number:
Sample Source: **New Well**
Sampling Point: **Well head**
Well Permit Number:
09100110172

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Darneice Lyons	04/22/2010
<i>E. coli</i> , Colilert	Absent	Darneice Lyons	04/22/2010

Report Date: 04/22/2010

Reported By: Joy Hayes

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.