



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - SUITE 1

HENDERSONVILLE, NC 28792
EIN:566000307EH

COURIER #: 06-92-01

Name of System:

JASON AND CARRIE GASPERSON

70 MILL KNOB
MILLS RIVER, NC

StarLIMS Sample ID: ES042414-0052001



Collected: 04/23/2014 08:43
Received: 04/24/2014 09:20

Curt Cline
Kathy Schnizler

ES Microbiology ID:
GPS Number:

Sample Source: New Well
Sampling Point: Well

Well Permit Number:
13120115603

Sample Description:
Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Susan Beasley	04/25/2014
<i>E. coli</i> , Colilert	Absent	Susan Beasley	04/25/2014

Report Date: 05/01/2014

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.