



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
HENDERSONVILLE, NC 28792
EIN:566000307EH

Name of System:
ANGELA CATHCART
130 GARDEN VIEW LN
HENDERSONVILLE, NC 28792
COURIER #: 06-92-01

StarLiMS Sample ID: **ES042617-0054001**

Collected: 04/25/2017 08:17 **Jerry R Robinson**
Received: 04/26/2017 08:28 **Angela Heybroek**

ES Microbiology ID:
GPS Number:

Sample Source: **New Well**
Sampling Point: **Well tap**
Well Permit Number: **15120116516**

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

| Analyte | Test Result | Date |
|---------------------------|--------------------|-------------|
| Total Coliform, Colilert | Absent | 04/27/2017 |
| <i>E. coli</i> , Colilert | Absent | 04/27/2017 |

Report Date: 04/28/2017

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.