



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.state.nc.us>  
Phone: 919-733-7834  
Fax: 919-733-8695

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - SUITE 100  
HENDERSONVILLE, NC 28792

Name of System:

LARRY ROCKLIN

144 BEREAL CHURCH RD  
FLAT ROCK, NC

StarLiMS Sample ID: **ES042810-0087001**

Collected: 04/27/2010 09:00 Krissie Red  
Received: 04/28/2010 09:20 Angela Heybroek

ES Microbiology ID: **16141**  
GPS Number:  
Sample Source: **New Well**  
Sampling Point: **Well** Well Permit Number:  
**10100100915**

Sample Description:

Comment:

**Environmental Microbiology - Colilert Profile**

**Method:** SM 9223B

**Test Name:** Colilert

<b>Analyte</b>	<b>Test Result</b>	<b>Analyst</b>	<b>Date</b>
Total Coliform, Colilert	Absent	Darneice Lyons	04/29/2010
<i>E. coli</i> , Colilert	Absent	Darneice Lyons	04/29/2010

**Report Date:** 04/29/2010

**Reported By:** Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.