



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7834  
Fax: 919-733-8695

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - SUITE 100  
HENDERSONVILLE, NC 28792  
EIN:566000307EH

Name of System:

DAVID PITTMAN

114 LYNNWOOD LANE  
HENDERSONVILLE, NC 28792

StarLIMS Sample ID: **ES042811-0069001**



Collected: 04/27/2011 09:05

Received: 04/28/2011 08:05

Krissie Red

Angela Heybroek

ES Microbiology ID: **26663**

GPS Number:

Sample Source: **New Well**

Sampling Point: **Well**

Well Permit Number:

**11100101589**

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

| Analyte                   | Test Result | Analyst       | Date       |
|---------------------------|-------------|---------------|------------|
| Total Coliform, Colilert  | Absent      | Susan Beasley | 04/29/2011 |
| <i>E. coli</i> , Colilert | Absent      | Susan Beasley | 04/29/2011 |

Report Date: 04/29/2011

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.