



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.state.nc.us>  
Phone: 919-733-7834  
Fax: 919-733-8695

Report To:

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - SUITE 100  
HENDERSONVILLE, NC 28792

HENDERSON MEAT PROCESSING  
911 STATON RD  
FLAT ROCK, NC 28731

StarLiMS Sample ID: **ES042910-0090001**

Collected: 04/28/2010 08:00  
Received: 04/29/2010 08:03

**Joy Hayes**

ES Microbiology ID: **16200**  
GPS Number:

Sample Source: **Well**  
Sampling Point: **Sink tap**

Sample Description:

Comment:

**Environmental Microbiology - Colilert Profile**

**Method:** SM 9223B

**Test Name:** Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Present	Joy Hayes	04/30/2010
<i>E. coli</i> , Colilert	Absent	Joy Hayes	04/30/2010

Report Date: 04/30/2010

Reported By: **Susan Beasley**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.