



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
4312 District Drive  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

Report To:  
**HENDERSON CO ENVIRONMENTAL HEALTH**  
**1200 SPARTANBURG HWY - STE 100**  
**HENDERSONVILLE, NC 28792**  
**EIN:566000307EH**

Name of System:  
**J.G. BURNETT**  
**54 W. BLACKWELL DR.**  
**HENDERSONVILLE, NC**  
**COURIER #: 06-92-01**

StarLiMS Sample ID: **ES050316-0096001**

Collected: 05/02/2016 08:29 **Curt Cline**  
Received: 05/03/2016 08:22 **Angela Heybroek**

ES Microbiology ID:  
GPS Number:

Sample Source: **New Well** Well Permit Number:  
Sampling Point: **well** **15100116357**

Sample Description:

Comment:

**Environmental Microbiology - Colilert Profile**

**Method:** SM 9223B

**Test Name:** Colilert

<b>Analyte</b>	<b>Test Result</b>	<b>Analyst</b>	<b>Date</b>
Total Coliform, Colilert	Absent	Denise Richardson	05/04/2016
<i>E. coli</i> , Colilert	Absent	Denise Richardson	05/04/2016

**Report Date:** 05/05/2016

**Reported By:** Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.