



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To: Name of System:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100 CMH HOMES
HENDERSONVILLE, NC 28792 201 WINDY ACRES DR.
EIN:566000307EH COURIER #: 06-92-01 **HENDERSONVILLE, NC**

StarLiMS Sample ID: **ES052616-0080001** Collected: 05/25/2016 08:30 **David Cumbee**
 Received: 05/26/2016 08:20 **Angela Heybroek**
ES Microbiology ID: Sample Source: **New Well** Well Permit Number:
GPS Number: Sampling Point: **spigot @ well** **15120112129**

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Denise Richardson	05/27/2016
<i>E. coli</i> , Colilert	Absent	Denise Richardson	05/27/2016

Report Date: 05/31/2016

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.