



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - SUITE 1

HENDERSONVILLE, NC 28792
EIN:566000307EH

COURIER #: 06-92-01

Name of System:
MARK JACKSON

123 MORGAN CREEK CT.
SALUDA, NC 28773

StarLiMS Sample ID: **ES052913-0058001**

Collected: 05/28/2013 08:51
Received: 05/29/2013 08:45 Analyst: **Angela Heybroek**

ES Microbiology ID:
GPS Number:

Sample Source: **New Well** Well Permit Number:
Sampling Point: **Well** **11120103452**

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile Method: SM 9223B

Test Name: **Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Darneice Lyons	05/30/2013
E. coli, Colilert	Absent	Darneice Lyons	05/30/2013

Report Date: 06/03/2013

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.