



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - SUITE 100
HENDERSONVILLE, NC 28792
EIN:566000307EH

Name of System:

DAVID COTTEN MIGRANT CAMP
823 APPLE VALLEY RD
HENDERSONVILLE, NC 28792

StarLIMS Sample ID: ES060911-0041001



Collected: 06/08/2011 08:46

Received: 06/09/2011 07:51

Curt Cline

Joy Hayes

ES Microbiology ID: 27712

GPS Number:

Sample Source: Well

Sampling Point: Kitchen

Well Permit Number:

Sample Description: Large Block bldg

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Joy Hayes	06/10/2011
<i>E. coli</i> , Colilert	Absent	Joy Hayes	06/10/2011

Report Date: 06/10/2011

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.