



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - SUITE 1

HENDERSONVILLE, NC 28792
EIN:566000307EH

COURIER #: 06-92-01

Name of System:

JOHN FERNANDEZ

1800 MIDDLE FORK RD
HENDERSONVILLE, NC 28792

StarLIMS Sample ID: **ES060915-0083001**



Collected: 06/08/2015 08:51

Received: 06/09/2015 10:19

Curt Cline

Kathy Schnizler

ES Microbiology ID:

GPS Number:

Sample Source: **Well**

Sampling Point: **outside tap**

Well Permit Number:

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Susan Beasley	06/10/2015
<i>E. coli</i> , Colilert	Absent	Susan Beasley	06/10/2015

Report Date: 06/11/2015

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.