



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100

Name of System:
RICHARD CLAUSON

800 HARPER RD.

HENDERSONVILLE, NC 28792
EIN:566000307EH

COURIER #: 06-92-01

StarLIMS Sample ID: **ES061317-0095001**



Collected: 06/12/2017 09:15
Received: 06/13/2017 08:28

Trenton Hill
Susan Beasley

ES Microbiology ID:
GPS Number:

Sample Source: **New Well**
Sampling Point: **well head**

Well Permit Number:
16100114166

Sample Description:
Comment:

Environmental Microbiology - Colisure Profile

Method: SM 9223B

Test Name: Water - Colisure

Analyte	Test Result	Date
Total Coliform, Colisure	Absent	06/14/2017
<i>E. coli</i> , Colisure	Absent	06/14/2017

Report Date: 06/15/2017

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.