



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7834  
Fax: 919-733-8695

---

Report To: **HENDERSON CO ENVIRONMENTAL HEALTH** Name of System: **GUO DEHU**  
**1200 SPARTANBURG HWY - SUITE 100** **27 COUNTRY ROAD**  
**HENDERSONVILLE, NC 28792** **HENDERSONVILLE, NC**  
**EIN:566000307EH**

---

StarLiMS Sample ID: **ES061611-0068001** Collected: **06/15/2011** 09:00 **Krissie Red**  
 Received: **06/16/2011** 07:54 **Joy Hayes**  
ES Microbiology ID: **27937** Sample Source: **Well** Well Permit Number: **SM 9223B**  
GPS Number: Sampling Point: **Kitchen**

Sample Description:

Comment:

---

**Environmental Microbiology - Colilert Profile** Method: **SM 9223B**

---

Test Name: **Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Joy Hayes	06/17/2011
<i>E. coli</i> , Colilert	Absent	Joy Hayes	06/17/2011

Report Date: **06/17/2011**

Reported By: **Susan Beasley**



**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.