



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To: Name of System:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
HENDERSONVILLE, NC 28792
EIN:566000307EH **COURIER #: 06-92-01**

D & M ORCHARDS MIGRANT CAMP
BEHIND #30 OTTANOLA RD
HENDERSONVILLE, NC 28792

StarLiMS Sample ID: **ES062116-0064001** Collected: 06/20/2016 08:49 **Curt Cline**
 Received: 06/21/2016 08:18 **Susan Beasley**

ES Microbiology ID: Sample Source: **Spring** Well Permit Number:
GPS Number: Sampling Point: **Kitchen**

Sample Description:
Comment: Resample; Spring with UV light treatment system

Environmental Microbiology - Colilert Profile **Method: SM 9223B**

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Susan Beasley	06/22/2016
<i>E. coli</i> , Colilert	Absent	Susan Beasley	06/22/2016

Report Date: 06/24/2016

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.