



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
HENDERSONVILLE, NC 28792
EIN:566000307EH

Name of System:
JUAN RAMIREZ
238 HOWARD GILBERT LN
COURIER #: 06-92-01

StarLiMS Sample ID: **ES062118-0008001**

Collected: 06/20/2018 09:00
Received: 06/21/2018 07:54
Cody Robertson
Denise Richardson

ES Microbiology ID:
GPS Number:

Sample Source: **Well**
Sampling Point: **Outside tap**
Well Permit Number:

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Date
Total Coliform, Colilert	Absent	06/22/2018
<i>E. coli</i> , Colilert	Absent	06/22/2018

Report Date: 06/25/2018

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.