



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100

Name of System:

CHRISTOPHER PANTZIS

242 FERN COVE LN

HENDERSONVILLE, NC 28792

EIN:566000307EH

COURIER #: 06-92-01

StarLIMS Sample ID: ES062718-0102001



Collected: 06/26/2018 08:52

Received: 06/27/2018 08:40

Jessica Shaw

Susan Beasley

ES Microbiology ID:

Sample Source: New Well

Well Permit Number:

GPS Number:

Sampling Point: Well head

17100108922

Sample Description:

Comment:

Environmental Microbiology - Colisure Profile

Method: SM 9223B

Test Name: Water - Colisure

Analyte	Test Result	Date
Total Coliform, Colisure	Absent	06/28/2018
<i>E. coli</i> , Colisure	Absent	06/28/2018

Report Date: 07/02/2018

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.