



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.state.nc.us>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH

DENNIS MCCRAW

1200 SPARTANBURG HWY - SUITE 100
HENDERSONVILLE, NC 28792

10172 BOYLSTON HWY
MILLS RIVER, NC

StarLiMS Sample ID: **ES062910-0050001**

Collected: 06/28/2010 08:32
Received: 06/29/2010 08:47

ES Microbiology ID: **18030**
GPS Number:
Sample Source: **New Well**
Sampling Point: **Well**

Krissie Red
Angela Heybroek

Well Permit Number:
08100113865

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Darneice Lyons	06/30/2010
<i>E. coli</i> , Colilert	Absent	Darneice Lyons	06/30/2010

Report Date: 07/06/2010

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.