



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.state.nc.us>  
Phone: 919-733-7834  
Fax: 919-733-8695

Report To:

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH

MARK YOKLEY

1200 SPARTANBURG HWY - SUITE 100  
HENDERSONVILLE, NC 28792

40 FORGE VALLEY DR.  
MILLS RIVER, NC

StarLiMS Sample ID: **ES070110-0072001**

Collected: 06/30/2010 08:30  
Received: 07/01/2010 08:18  
**Krissie Red  
Darneice Lyons**

ES Microbiology ID: **18150**  
GPS Number:  
Sample Source: **Well**  
Sampling Point: **Well**  
Well Permit Number:

Sample Description:

Comment:

**Environmental Microbiology - Colilert Profile**

**Method:** SM 9223B

**Test Name:** Colilert

<b>Analyte</b>	<b>Test Result</b>	<b>Analyst</b>	<b>Date</b>
Total Coliform, Colilert	Absent	Darneice Lyons	07/02/2010
<i>E. coli</i> , Colilert	Absent	Darneice Lyons	07/02/2010

**Report Date:** 07/06/2010

**Reported By:** Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.