



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - SUITE 1

HENDERSONVILLE, NC 28792
EIN:566000307EH

COURIER #: 06-92-01

Name of System:
J B MORGAN

260 WATER'S EDGE LOOP
HENDERSON, NC 27537

StarLIMS Sample ID: **ES070213-0038001**



Collected: 07/01/2013 11:00

Received: 07/02/2013 08:30

Chris Hedrick

Holly Braswell

ES Microbiology ID:

Sample Source: **Well**

Well Permit Number:

GPS Number:

Sampling Point: **Well head**

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: **Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	HLBRASWELL	07/03/2013
<i>E. coli</i> , Colilert	Absent	HLBRASWELL	07/03/2013

Report Date: 07/05/2013

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.