

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: Moore
Water System ID #: 03-63-537
Name of System: Stone's Chapel
Sample Type: 5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: 07/06/11 TIME: 15:00 PM
Location where collected: Kit. Tap
Location Type: 2 (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: _____ Collected By: Carlton Smith

FOR REPEAT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity: ☐ (1 = Same; 2 = Upstream; 3 = Downstream)

FOR REPLACEMENT SAMPLE:

Original Sample Type: ☐
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time: _____

Mail Results To:

FAYETTEVILLE REGIONAL OFFICE PWSS
225 GREEN STREET
FAYETTEVILLE, 28301-5043

Telephone No. **910-433-3000**

Type of Supply:

☐ Community ☐ NTNC
☒ Non-Community ☐ Private

Type of Treatment:

☐ Chlorinated
☒ Non-Chlorinated
Free Chlorine Residual: 0 mg/l
Total Chlorine Residual: _____

RESULTS

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	<u>9223B</u>	☒	☐	☐
Fecal/E. Coli	<u>9223B</u>	☐	☒	☐
Heterotrophic P.C.	_____	_____	_____ /ml	_____

(number)

☐ Repeat Samples Required

Date Analysis Begun: 07/07/11
Date Analysis Completed: 07/08/11
Laboratory Log #: 28396

COMMENTS: _____

INVALID CODES

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

☐ Replacement Samples Required

Time Analysis Begun: 09:05 AM
Time Analysis Completed: 09:10 AM
Certified By: Susan Beasley

