

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: CASWELL
Water System ID #: 30-17-052
Name of System: DOLLAR GENERAL STORE # 13809
Sample Type: 5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: 07/11/16 TIME: 14:28 PM
Location where collected: OUTSIDE SPIGOT NORTH
Location Type: (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: 051 Collected By: J Bryan

FOR REPEAT SAMPLE:

FOR REPLACEMENT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity: (1 = Same; 2 = Upstream; 3 = Downstream)

Original Sample Type:
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time: _____

Mail Results To:
WINSTON SALEM REGIONAL OFFICE
450 WEST HANES MILL RD STE 300
WINSTON SALEM, NC 27105
Telephone No. 3367715000
EIN #: 566000372X

Type of Supply:
 Community NTNC
 Non-Community Private
Type of Treatment: Chlorinated
 Non-Chlorinated
Free Chlorine Residual: _____ 0 mg/l
Total Chlorine Residual: _____ 0 mg/l

RESULTS

INVALID CODES

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	<u>9223B</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Fecal/E. Coli	_____	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heterotrophic P.C.	_____	_____/ml		
		(number)		

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

Repeat Samples Required

Replacement Samples Required

Date Analysis Begun: 07/12/16
Date Analysis Completed: 07/13/16
Laboratory Log #: _____

Time Analysis Begun: 08:15 AM
Time Analysis Completed: 08:20 AM
Certified By: Susan Beasley

COMMENTS: Special / Non-compliance (SP), System Type: TNC, Water Source: GW

