



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.state.nc.us>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - SUITE 100
HENDERSONVILLE, NC 28792

BOB CAMPBELL YOUTH CAMPUS
P.O. BOX 250
HENDERSONVILLE, NC 28793

StarLiMS Sample ID: **ES071310-0087001**

Collected: 07/12/2010 08:20
Received: 07/13/2010 08:00
Analyst: **Garrett Rapp**
Comments: **Darneice Lyons**

ES Microbiology ID: **18386**
GPS Number:
Sample Source: **Well**
Sampling Point: **Kitchen tap**
Well Permit Number:

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Susan Beasley	07/14/2010
<i>E. coli</i> , Colilert	Absent	Susan Beasley	07/14/2010

Report Date: 07/15/2010

Reported By: Joy Hayes

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.