



North Carolina State Laboratory Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.state.nc.us>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:**HENDERSON CO ENVIRONMENTAL HEALTH****1200 SPARTANBURG HWY - SUITE 100
HENDERSONVILLE, NC 28792****Name of System:****SEAN MONAGHAN****406 PATTERSON RD.
HENDERSONVILLE, NC 28792**StarLIMS Sample ID: **ES071310-0089001**

Collected: 07/12/2010 08:00

Received: 07/13/2010 08:00

Curt Cline**Darneice Lyons**ES Microbiology ID: **18388**

GPS Number:

Sample Source: **Well**Sampling Point: **Outside tap**

Well Permit Number:

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile**Method:** SM 9223B**Test Name: Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Susan Beasley	07/14/2010
<i>E. coli</i> , Colilert	Absent	Susan Beasley	07/14/2010

Report Date: 07/15/2010**Reported By:** **Joy Hayes****Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.