

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: **37501** County: **Moore**
Water System ID #: **03-63-623**
Name of System: **Eagle Springs Service Center**
Sample Type: **5** (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: **07/13/11** TIME: **14:20 PM**
Location where collected: **Kit Wash Sink (2 Comp)**
Location Type: **2** (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: _____ Collected By: **Carlton Smith**

FOR REPEAT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity: ☐ (1 = Same; 2 = Upstream; 3 = Downstream)

FOR REPLACEMENT SAMPLE:

Original Sample Type: ☐
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time: _____

Mail Results To:

**FAYETTEVILLE REGIONAL OFFICE PWSS
225 GREEN STREET
FAYETTEVILLE, 28301-5043**

Telephone No. 910-433-3000

Type of Supply:

☐ Community ☐ NTNC
☒ Non-Community ☐ Private

Type of Treatment:

☐ Chlorinated
☒ Non-Chlorinated
Free Chlorine Residual: 0.0 mg/l
Total Chlorine Residual: _____

RESULTS

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	9223B	☐	☒	☐
Fecal/E. Coli	_____	☐	☐	☐
Heterotrophic P.C.	_____	_____/ml (number)		

☐ Repeat Samples Required

Date Analysis Begun: **07/14/11**
Date Analysis Completed: **07/15/11**
Laboratory Log #: **28617**

COMMENTS: _____

INVALID CODES

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

☐ Replacement Samples Required

Time Analysis Begun: **08:45 AM**
Time Analysis Completed: **09:20 AM**
Certified By: **Joy Hayes**

