



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7834  
Fax: 919-733-8695

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - SUITE 100  
HENDERSONVILLE, NC 28792  
EIN:566000307EH

Name of System:

JIM HILL MIGRANT HOUSE  
2151 OLD CLEAR CREEK RD  
HENDERSONVILLE, NC 28792

StarLiMS Sample ID: **ES080211-0104001**

Collected: 08/01/2011 08:33  
Received: 08/02/2011 11:20

**Curt Cline**  
**Joy Hayes**

ES Microbiology ID: **29158**  
GPS Number:

Sample Source: **Well**  
Sampling Point: **Kitchen**

Well Permit Number:

Sample Description:

Comment:

**Environmental Microbiology - Colilert Profile**

**Method:** SM 9223B

**Test Name:** Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Present	Joy Hayes	08/03/2011
<i>E. coli</i> , Colilert	Absent	Joy Hayes	08/03/2011

Report Date: 08/04/2011

Reported By: Joy Hayes

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.