

### BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: RICHMOND  
Water System ID #: 03-77-109  
Name of System: RICHMOND COUNTY  
Sample Type:  5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)  
Collected on: DATE: 08/09/16 TIME: 15:10 PM  
Location where collected: 241 CHURCH ST  
Location Type:  (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)  
Location Code: \_\_\_\_\_ Collected By: T Overby

**FOR REPEAT SAMPLE:**

**FOR REPLACEMENT SAMPLE:**

Previous Positive Location Code: \_\_\_\_\_  
Positive Collection Date: \_\_\_\_\_  
Time: \_\_\_\_\_  
Proximity:  (1 = Same; 2 = Upstream; 3 = Downstream)

Original Sample Type:   
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)  
Original Collection Date: \_\_\_\_\_  
Time: \_\_\_\_\_

Mail Results To: **FAYETTEVILLE REGIONAL OFFICE PWSS**  
**225 GREEN ST STE 714**  
**FAYETTEVILLE, NC 28301**  
**Telephone No.**  
**EIN #: 562033116M** **COURIER #: 14-56-48**

Type of Supply:  Community  NTNC  
 Non-Community  Private

Type of Treatment:  Chlorinated  
 Non-Chlorinated  
Free Chlorine Residual: .35 mg/l  
Total Chlorine Residual: \_\_\_\_\_

**RESULTS**

**INVALID CODES**

| CONTAMINANT        | METHOD       | PRESENT                  | ABSENT                              | INVALID                  |
|--------------------|--------------|--------------------------|-------------------------------------|--------------------------|
| Total Coliform     | <u>9223B</u> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Fecal/E. Coli      | _____        | <input type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> |
| Heterotrophic P.C. | <u>9215B</u> | <u>43 CFU</u>            | /ml                                 |                          |
|                    |              | (number)                 |                                     |                          |

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

Repeat Samples Required

Replacement Samples Required

Date Analysis Begun: 08/10/16  
Date Analysis Completed: 08/11/16  
Laboratory Log #: \_\_\_\_\_

Time Analysis Begun: 10:05 AM  
Time Analysis Completed: 10:55 AM  
Certified By: Susan Beasley

COMMENTS: Special / Non-compliance (SP), Water Source: S. Disinfectant Used: Chlorine,  
Heterotrophic Place Count analysis started 08/10/16 @10:20AM and read  
08/12/16 @08:50AM by S. Beasley

