



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7834  
Fax: 919-733-8695

---

Report To: **HENDERSON CO ENVIRONMENTAL HEALTH** Name of System: **WARREN MORRIS**  
**1200 SPARTANBURG HWY - SUITE 100** **968 CRAB CREEK RD.**  
**HENDERSONVILLE, NC 28792** **HENDERSONVILLE, NC 28792**  
EIN:566000307EH COURIER #: 06-92-01

---

StarLiMS Sample ID: **ES082511-0074001** Collected: 08/24/2011 08:26 **Curt Cline**  
 Received: 08/25/2011 09:16 **Angela Heybroek**  
ES Microbiology ID: **29922** Sample Source: **New Well** Well Permit Number: **09100108832**  
GPS Number: Sampling Point: **Well**

Sample Description:

Comment:

---

**Environmental Microbiology - Colilert Profile** Method: SM 9223B

---

Test Name: **Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Present	Joy Hayes	08/26/2011
<i>E. coli</i> , Colilert	Absent	Joy Hayes	08/26/2011

Report Date: 08/30/2011

Reported By: Susan Beasley



**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.