



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To: Name of System:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100 **LAUGHTER FARMS MIGRANT HOUSING**
HENDERSONVILLE, NC 28792 **309 TULLAHOMA FARMS LN.**
EIN:566000307EH **COURIER #: 06-92-01** **HENDERSONVILLE, NC 28792**

StarLiMS Sample ID: **ES082715-0008001** Collected: 08/26/2015 09:21 **Curt Cline**
 Received: 08/27/2015 07:47 **Darneice Owens**
ES Microbiology ID: Sample Source: **Well** Well Permit Number:
GPS Number: Sampling Point: **kitchen**

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile Method: SM 9223B

Test Name: **Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Present	Denise Richardson	08/28/2015
<i>E. coli</i> , Colilert	Absent	Denise Richardson	08/28/2015

Report Date: 08/28/2015

Reported By: Susan Beasley



Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.