



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7834  
Fax: 919-733-8695

---

Report To: **HENDERSON CO ENVIRONMENTAL HEALTH** Name of System: **LINDSAY BRITTAIN HYDER**  
1200 SPARTANBURG HWY - SUITE 100 377 JACKSON LOOP RD  
HENDERSONVILLE, NC 28792 HENDERSONVILLE, NC 28792  
EIN:566000307EH COURIER #: 06-92-01

---

StarLiMS Sample ID: **ES083011-0101001** Collected: 08/29/2011 08:13 **Curt Cline**  
 Received: 08/30/2011 08:30 **Angela Heybroek**  
ES Microbiology ID: **29997** Sample Source: **New Well** Well Permit Number: **11120103974**  
GPS Number: Sampling Point: **Well**

Sample Description:

Comment:

**Environmental Microbiology - Colilert Profile** Method: SM 9223B

---

Test Name: **Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Present	Darneice Lyons	08/31/2011
<i>E. coli</i> , Colilert	Absent	Darneice Lyons	08/31/2011

Report Date: 09/01/2011

Reported By: Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.