



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
4312 District Drive  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

Report To:  
**HENDERSON CO ENVIRONMENTAL HEALTH**  
**1200 SPARTANBURG HWY - SUITE 1**

**HENDERSONVILLE, NC 28792**  
**EIN:566000307EH**

COURIER #: 06-92-01

Name of System:  
**WILLIAM KHUDSON**

**3538 BREVARD RD**  
**HENDERSONVILLE, NC 28791**

StarLIMS Sample ID: **ES090513-0072001**



Collected: 09/04/2013 09:03  
Received: 09/05/2013 09:00

**Curt Cline**  
**Darneice Lyons**

ES Microbiology ID:  
GPS Number:

Sample Source: **Well**  
Sampling Point: **Well**

Well Permit Number:

Sample Description:  
Comment:

**Environmental Microbiology - Colisure Profile**

Method: SM 9223B

Test Name: **Water - Colisure**

| Analyte                   | Test Result | Analyst        | Date       |
|---------------------------|-------------|----------------|------------|
| Total Coliform, Colisure  | Absent      | Darneice Lyons | 09/06/2013 |
| <i>E. coli</i> , Colisure | Absent      | Darneice Lyons | 09/06/2013 |

Report Date: 09/10/2013

Reported By: **Susan Beasley**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.