

### BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: ROCKINGHAM  
Water System ID #: 02-79-134  
Name of System: FAIRGROVE MHP  
Sample Type:  5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)  
Collected on: DATE: 09/07/16 TIME: 10:45 AM  
Location where collected: KITCHEN SINK  
Location Type:  (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)  
Location Code: 001 Collected By: Chris Lewter

**FOR REPEAT SAMPLE:**

Previous Positive Location Code: \_\_\_\_\_  
Positive Collection Date: \_\_\_\_\_  
Time: \_\_\_\_\_  
Proximity:   
(1 = Same; 2 = Upstream; 3 = Downstream)

**FOR REPLACEMENT SAMPLE:**

Original Sample Type:   
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)  
Original Collection Date: \_\_\_\_\_  
Time: \_\_\_\_\_

Mail Results To: **WINSTON SALEM REGIONAL OFFICE PWSS**  
**WINSTON SALEM, NC 27107-2241**  
**Telephone No. 336-771-5000**  
**EIN #: 56 6000372 XX COURIER #: 13-15-01**

Type of Supply:  Community  NTNC  
 Non-Community  Private

Type of Treatment:  Chlorinated  
 Non-Chlorinated  
Free Chlorine Residual: 2.2 mg/l  
Total Chlorine Residual: \_\_\_\_\_

**RESULTS**

| CONTAMINANT        | METHOD       | PRESENT                  | ABSENT                              | INVALID                  |
|--------------------|--------------|--------------------------|-------------------------------------|--------------------------|
| Total Coliform     | <u>9223B</u> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Fecal/E. Coli      | _____        | <input type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> |
| Heterotrophic P.C. | _____        | _____/ml                 |                                     |                          |
|                    |              | (number)                 |                                     |                          |

**INVALID CODES**

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

Repeat Samples Required

Replacement Samples Required

Date Analysis Begun: 09/08/16  
Date Analysis Completed: 09/09/16  
Laboratory Log #: \_\_\_\_\_

Time Analysis Begun: 09:00 AM  
Time Analysis Completed: 09:25 AM  
Certified By: Susan Beasley

COMMENTS: Special / Non-compliance (SP), System Type: C, Water Source: GW,  
Disinfectant Used: Sodium Hypochlorite

