

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: ALAMANCE
Water System ID #: 02-01-130
Name of System: SAXAPAHAW UTILITY COMPANY
Sample Type: 5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: 09/09/16 TIME: 09:00 AM
Location where collected: DOWNSTAIRS SINK
Location Type: (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: 002 Collected By: Shawn Fox

FOR REPEAT SAMPLE:

FOR REPLACEMENT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity:
(1 = Same; 2 = Upstream; 3 = Downstream)

Original Sample Type:
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time _____

Mail Results To: **WINSTON SALEM REGIONAL OFFICE PWSS**
WINSTON SALEM, NC 27107-2241
Telephone No. 336-771-5000
EIN #: 56 6000372 XX COURIER #: 13-15-01

Type of Supply: Community NTNC
 Non-Community Private

Type of Treatment: Chlorinated
 Non-Chlorinated
Free Chlorine Residual: 0.76 mg/l
Total Chlorine Residual: _____

RESULTS

INVALID CODES

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	_____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Fecal/E. Coli	_____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Heterotrophic P.C.	_____	_____/ml (number)		

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

Repeat Samples Required

Replacement Samples Required

Date Analysis Begun: _____
Date Analysis Completed: _____
Laboratory Log #: _____

Time Analysis Begun: _____ : **AM**
Time Analysis Completed: _____ : **AM**
Certified By: **Susan Beasley**

COMMENTS: Special/Non-compliance (SP), Water Source: GW, Sample over 30 hours old
when received; Water bacteriological sample must be collected on Monday,
Tuesday or Wednesday with receipt no later than Thursday.

