



North Carolina State Laboratory of Public Health

Environmental Sciences

Inorganic Chemistry

Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To: JOHNNY SUMMERLIN
DUPLIN CO ENVIRONMENTAL HEALTH
PO BOX 948

Name of System:
MARTINA TAURA

KENANSVILLE, NC 28349
EIN: 566000296EH

Courier # 52-41-41

139 CAROLINA WINDS DR
MOUNT OLIVE, NC 28365

StarLiMS ID: **ES091715-0055001**

Date Collected: 09/16/15

Time Collected: 1:30 PM

Date Received: 09/17/15

Collected By: Johnny Summerlin

Sample Type: Raw

Sampling Point: Well spigot (threadless)

Well Permit #: 332

Sample Source: New Well

Temp. at Receipt: 4.0

GPS #:

Sample Description:

Comment:

New Well I (Profile)

Analyte	Result	Allowable Limit	Unit	Qualifier(s)
Arsenic	< 0.005	0.010	mg/L	
Barium	< 0.1	2.00	mg/L	
Cadmium	< 0.001	0.005	mg/L	
Calcium	14		mg/L	
Chloride	< 5.00	250	mg/L	
Chromium	< 0.01	0.10	mg/L	
Copper	< 0.05	1.3	mg/L	
Fluoride	< 0.20	4.00	mg/L	
Iron	1.50	0.30	mg/L	
Lead	< 0.005	0.015	mg/L	
Magnesium	< 1.0		mg/L	
Manganese	0.10	0.05	mg/L	
Mercury	< 0.0005	0.002	mg/L	
Nitrate	< 1.00	10.00	mg/L	
Nitrite	< 0.10	1.00	mg/L	
pH	7.1		N/A	
Selenium	< 0.005	0.05	mg/L	
Silver	< 0.05	0.10	mg/L	
Sodium	2.50		mg/L	
Sulfate	< 5.00	250	mg/L	
Total Alkalinity	33		mg/L	
Total Hardness	37		mg/L	
Zinc	< 0.05	5.00	mg/L	

Report Date: 09/24/2015

Reported By: Arnold Hall