



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7834  
Fax: 919-733-8695

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - SUITE 100  
HENDERSONVILLE, NC 28792  
EIN:566000307EH

Name of System:

HENDERSONS MEATS  
911 STATON RD.  
FLAT ROCK, NC 28731

StarLiMS Sample ID: **ES092210-0082001**

Collected: 09/21/2010 08:00  
Received: 09/22/2010 08:26 Analyst: **Valerie Yager**

ES Microbiology ID: **20810**  
GPS Number:  
Sample Source: **Well**  
Sampling Point: **Sink Tap** Well Permit Number:

Sample Description:

Comment:

**Environmental Microbiology - Colilert Profile** Method: SM 9223B

Test Name: **Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Valerie Yager	09/23/2010
<i>E. coli</i> , Colilert	Absent	Valerie Yager	09/23/2010

Report Date: 09/23/2010

Reported By: **Susan Beasley**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.