



North Carolina State Laboratory Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7834  
Fax: 919-733-8695

Report To:  
HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - SUITE 1

HENDERSONVILLE, NC 28792  
EIN:566000307EH

COURIER #: 06-92-01

Name of System:  
JACKIE GOLDEN

18 INDEPENDENCE LN.  
MILLS RIVER, NC

StarLIMS Sample ID: **ES092612-0156001**

Collected: 09/25/2012 08:46  
Received: 09/26/2012 09:05

Curt Cline  
Angela Heybroek

ES Microbiology ID: **40052**  
GPS Number:

Sample Source: **New Well**  
Sampling Point: **Well**

Well Permit Number:  
**12120106870**

Sample Description:  
Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

| Analyte                   | Test Result | Analyst       | Date       |
|---------------------------|-------------|---------------|------------|
| Total Coliform, Colilert  | Present     | Susan Beasley | 09/27/2012 |
| <i>E. coli</i> , Colilert | Absent      | Susan Beasley | 09/27/2012 |

Report Date: 10/02/2012

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.