



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7834
Fax: 919-733-8695

Report To: **HENDERSON CO ENVIRONMENTAL HEALTH** Name of System: **BARBARA SHACKLEFORD**
1200 SPARTANBURG HWY - SUITE 100 **110 EAST GLENWOOD LN**
HENDERSONVILLE, NC 28792 **HENDERSONVILLE, NC 28792**
EIN:566000307EH

StarLiMS Sample ID: **ES092910-0119001** Collected: 09/28/2010 08:44 Krissie Red
 Received: 09/29/2010 09:09 Angela Heybroek
ES Microbiology ID: **21061** Sample Source: **New Well** Well Permit Number: **09100106715**
GPS Number: Sampling Point: **Well**

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile Method: SM 9223B

Test Name: **Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Present	Valerie Yager	09/30/2010
<i>E. coli</i> , Colilert	Absent	Valerie Yager	09/30/2010

Report Date: 10/01/2010

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.