N.C. Department of Environmental, Health, and Natural Resources
Division of Laboratory Services
State Laborabory of Public Health
P.O.Box 28047 - 4312 District Drive
Raleigh, NC 27611-8047
919-733-7308

DO NOT WRITE IN THIS SPACE

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #:   **3 7 5 0 1**   County: **GUILFORD**

Water System ID #:   **30-41-050**

Name of System: **CLAPPS NURSING CTR - APPOMATTOX**

Sample Type: **5**   (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)

Collected on: DATE: **09/28/16**   TIME: **11:06 AM**

Location where collected: **KITCHEN TAP**

Location Type: ☐   (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)

Location Code: **D01**   Collected By: **Mike Painter**

FOR REPEAT SAMPLE:

Previous Positive Location Code: _____

Positive Collection Date: _____

Time: _____

Proximity: ☐
(1 = Same; 2 = Upstream; 3 = Downstream)

FOR REPLACEMENT SAMPLE:

Original Sample Type: ☐

(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)

Original Collection Date: _____

Time _____

Mail Results To:

WINSTON SALEM REGIONAL OFFICE PWSS

450 WEST HANES MILL RD STE 300

WINSTON SALEM, NC 27105

Telephone No.   3367715000

EIN #: 566000372X

Type of Supply:

☒ Community   ☐ NTNC

☐ Non-Community   ☐ Private

Type of Treatment: ☐ Chlorinated

☐ Non-Chlorinated

Free Chlorine Residual: 1.13 mg/l

Total Chlorine Residual: _____

RESULTS

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	**9223B**	☐	☒	☐
Fecal/E. Coli		☐	☐	☐
Heterotrophic P.C.	_____	_____ /ml		
		(number)		

INVALID CODES

1) Confluent Growth/No Coliform Found
2) TNTC/No Coliform Found
3) Turbid Culture/No Coliform Found
4) Over 30 Hours Old
5) Improper Sample or Analysis

☐ Repeat Samples Required   ☐ Replacement Samples Required

Date Analysis Begun: **09/29/16**   Time Analysis Begun: **07:50 AM**

Date Analysis Completed: **09/30/16**   Time Analysis Completed: **08:00 AM**

Laboratory Log #: _____   Certified By: **Susan Beasley**

COMMENTS: Special / Non-compliance (SP), Water Source: GW, Disinfectant Used: Chlorine