

N.C. Department of Environmental, Health, and Natural Resources
Division of Laboratory Services
State Laboratory of Public Health
P.O.Box 28047 - 4312 District Drive
Raleigh, NC 27611-8047
919-733-7308

DO NOT WRITE IN THIS SPACE

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: CUMBERLAND
Water System ID #: 50-26-028
Name of System: NEW VISION CHURCH
Sample Type: 5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: 10/06/15 TIME: 09:10 AM
Location where collected: KITCHEN HAND SINK
Location Type: (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: _____ Collected By: Carlton Smith

FOR REPEAT SAMPLE:

FOR REPLACEMENT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity: (1 = Same; 2 = Upstream; 3 = Downstream)

Original Sample Type:
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time _____

Mail Results To:
FAYETTEVILLE REGIONAL OFFICE PWSS
225 GREEN ST STE 714
FAYETTEVILLE, NC 28301
Telephone No.
EIN #: 562033116M **COURIER #: 14-56-48**

Type of Supply:
 Community NTNC
 Non-Community Private
Type of Treatment: Chlorinated
 Non-Chlorinated
Free Chlorine Residual: _____
Total Chlorine Residual: _____

RESULTS

INVALID CODES

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	<u>9223B</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fecal/E. Coli	<u>9223B</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Heterotrophic P.C.	_____	_____	_____ /ml	_____

(number)

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

Repeat Samples Required

Replacement Samples Required

Date Analysis Begun: 10/07/15
Date Analysis Completed: 10/08/15
Laboratory Log #: _____

Time Analysis Begun: 08:40 AM
Time Analysis Completed: 08:40 AM
Certified By: Susan Beasley

COMMENTS: Special / Non-compliance (SP), System Type: TNC, Water Source: GW.

